

FECAL ACCIDENT RESPONSE

<u>SOLID STOOLS</u>	<u>DIARRHEA</u>
<u>1</u> EVACUATE ALL PATRONS FROM POOLS ON SAME FILTER	<u>1</u> EVACUATE ALL PATRONS FROM POOLS ON SAME FILTER
<u>2</u> REMOVE AS MUCH FECAL MATTER AS POSSIBLE (NET OR SCOOP) (VACUUMING NOT RECOMMENDED)	<u>2</u> REMOVE AS MUCH FECAL MATTER AS POSSIBLE (NET/SCOOP) (VACUUMING NOT RECOMMENDED)
<u>3</u> RAISE CHLORINE TO 2.0PPM, PH 7.2-7.5	<u>3</u> RAISE CHLORINE TO 2.0PPM, PH 7.2-7.5. MAINTAIN FOR A MINIMUM OF 8 HOURS.
<u>4</u> MAINTAIN CHEMICAL LEVELS FOR 30 MINUTES	<u>4</u> ENSURE FILTRATION SYSTEM IS OPERATING WHILE POOL REACHES AND MAINTAINS CHLORINE DISINFECTION
<u>5</u> DOCUMENT ACCIDENT: DATE, TIME, TYPE, CHLORINE LEVEL AT THE TIME OF EVENT. *NOTIFY HEALTH DEPT*	<u>5</u> BACKWASH FILTER THOROUGHLY.
<u>6</u> PRIOR TO REOPENING: RECORD CHLORINE, PH, STEPS TAKEN, LENGTH OF TIME CHLORINE > 2.0 PPM	<u>6</u> DOCUMENT ACCIDENT: DATE, TIME, TYPE, CHLORINE LEVEL AT THE TIME OF EVENT. *NOTIFY HEALTH DEPT*
	<u>7</u> PRIOR TO REOPENING: RECORD CHLORINE, PH, STEPS TAKEN, TIME CHLORINE > 2.0PPM

**CONTACT THE PORTSMOUTH HEALTH DEPARTMENT'S
ENVIRONMENTAL HEALTH OFFICE
FOR ALL POOL QUESTIONS
393-8585 EXT. 8585**